

# EU type examination certificate

## EU-Baumusterprüfbescheinigung

CE-0085CT0650

Product Identification No.  
Produkt-Identnummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
<b>Distributor</b> <i>Vertreiber</i>	Ferrolì S.p.A. Via Ritonda 78A, I-37047 San Bonifacio (VR)
<b>Product Category</b> <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
<b>Product description</b> <i>Produktbezeichnung</i>	Condensing combi water heater optional also as condensing water heater
<b>Model</b> <i>Modell</i>	LAMBORGHINI CALORECLIMA ALHENA TECH/IDOLA S HYBRID...
<b>Countries of Destination</b> <i>Bestimmungsländer</i>	AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NL, NO, PL, PT, RO, SE, SI, SK, TR
<b>Test reports</b> <i>Prüfberichte</i>	Supplement test: K 3026 2023 B23 from 31.05.2023 (TRG) Supplement test: K 3026 2023 E22 from 31.05.2023 (TRG)
<b>Test basis</b> <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 15502-1 (01.02.2022) DIN EN 15502-2-1 (01.11.2022) DVGW CERT ZP 3100-20 (01.12.2022)
<b>Date of Expiry / File No.</b> <i>Ablaufdatum / AZ</i>	14.06.2031 / 22-0646-GER



70225-04-A-05

12.07.2023 Kir B-1/2 20.7.  
Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH - notified by the government of the Federal Republic of Germany and officially registered by the European Commission for conformity assessment of gas appliances

DVGW CERT GmbH – von der Deutschen Bundesregierung benannte und von der Europäischen Kommission offiziell registrierte Stelle für die Konformitätsbewertung von Gasgeräten

DVGW CERT GmbH  
Zertifizierungsstelle  
Josef-Wirmer-Str. 1-3  
53123 Bonn  
Tel. +49 228 91 88 - 888  
Fax +49 228 91 88 - 993  
www.dvgw-cert.com  
info@dvgw-cert.com

Appliance Categories <i>Gerätekategorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
I2E	20 mbar	DE, LU, RO	
I2ELwLs	20,20,13 mbar	PL	
I2H	20 mbar	CZ, ES, GR, NL	
I3B/P	30 mbar	BE, PT	
I3B/P	50 mbar	DE, GR	
I12E+3+	20/25, 28-30/37 mbar	BE, FR	
I12E+3B/P	20/25, 37 mbar	FR	
I12E+3P	20/25, 37 mbar	BE	
I12E3B/P	20, 50 mbar	DE	
I12E3B/P	20, 30 mbar	PL	
I12EK3B/P	25, 30 mbar	NL	
I12ELL3B/P	20, 50 mbar	DE	
I12ELwLs3B/P	20,20,13, 30 mbar	PL	
I12H3+	20, 28-30/37 mbar	CH, CY, CZ, ES, GB, GR, IE, IT, LT, PT, SI, SK	
I12H3+	20, 30/37 mbar	TR	
I12H3B/P	20, 30 mbar	CY, CZ, DK, EE, FI, HR, HU, IS, IT, LT, NO, RO, SE, SI, SK	
I12H3B/P	20, 37 mbar	HR, LV, TR	
I12H3B/P	20, 50 mbar	AT, CH, GR, LU, SK	
I12H3P	20, 37 mbar	ES, GB, IE, PT	
I12HM3+	20, 28-30/37 mbar	IT	
I12HM3B/P	20, 30 mbar	IT	
I12HM3B/P	20, 37 mbar	IT	
I12HM3P	20, 30 mbar	IT	
I12HM3P	20, 37 mbar	IT	
I12HS3B/P	25, 30 mbar	HU	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
...ALHENA TECH 24 C	Nominal heat output: 2,8...24,5 kW Heat input (Hi): 2,9...25,0 (DHW.: ...25,0) kW	
...ALHENA TECH 28 C/K 50	Nominal heat output: 2,8...28,0 kW Heat input (Hi): 2,9...28,5 (DHW.: ...28,5) kW	
...ALHENA TECH 34 C/K 50; B 34 K 50	Nominal heat output: 2,8...34,0 kW Heat input (Hi): 2,9...34,7 (DHW.: ...34,7) kW	
... ALHENA TECH 28 H	Nominal heat output: 2,8...28,0 kW Heat input (Hi): 2,9...28,5 kW	
...ALHENA TECH 34 H/B 34	Nominal heat output: 2,8...34,0 kW Heat input (Hi): 2,9...34,7 kW	
...ALHENA TECH 45 H	Nominal heat output: 6,3...42,9 kW Heat input (Hi): 6,4...43,8 kW	
...IDOLA S HYBRID 28C 3.2 UI 6/10	Nominal heat output: 2,8...28,0 kW Heat input (Hi): 2,9...28,5 (DHW.: ...28,5) kW	
...IDOLA S HYBRID 28H 3.2 UI 6/10	Nominal heat output: 2,8...28,0 kW Heat input (Hi): 2,9...28,5 kW	

Type Variation <i>Ausführungsvariante</i>	Explanations <i>Erläuterungen</i>
...C; ...C...	condensing combi water heater
...H	condensing water heater
...K 50	with hot water storage tank (50 liters)
...B	floor standing

### Hints of Utilization /Remarks

#### Verwendungshinweise / Bemerkungen

Electrical data: 230 V AC, 50 Hz

Flue types B23, B33, C(10)3, C(11)3, C13, C23, C33, C43, C53, C63, C83, C93: according to installation manual with flue system of Gropballi (2592-CPR-001)

Approved appliance categories, supply pressures and countries of destination: AL, MK: I12E3B/P (20, 50 mbar); BG, MT: I12H3B/P (20, 30 mbar); ES, FR, GR, PT: I2N (20 mbar); FR: I2N (25 mbar); FR: I2H (20/25); BE, SI: I2N (20 mbar); ES, IE: I3B (30 mbar); NL: I12L3B/P (25, 30)

In non-EU countries, the conformity approval will only be accepted once the Gas Appliance Regulation EU/2016/426 will be transferred into national law.

The boilers are qualified for the addition of up to 20 vol.-% hydrogen to natural gas (G20) as burning gas.